

GEOLOGICAL SURVEY CIRCULAR 398



ESTIMATED USE OF WATER IN THE
UNITED STATES, 1955

UNITED STATES DEPARTMENT OF THE INTERIOR

Fred A. Seaton, *Secretary*

GEOLOGICAL SURVEY

Thomas B. Nolan, *Director*

GEOLOGICAL SURVEY CIRCULAR 398

ESTIMATED USE OF WATER IN THE UNITED STATES, 1955

By Kenneth A. MacKichan

Washington, D. C., 1957

Free on application to the Geological Survey, Washington 25, D. C.

CONTENTS

	Page		Page
Abstract.....	1	Withdrawal use—Continued	
Introduction	1	Summary of withdrawals.....	7
Previous investigations	1	Nonwithdrawal uses.....	12
Present investigation	1	Consumptive use.....	12
Definition of terms	2	Public supplies.....	12
Withdrawal use	2	Rural	12
Public supplies	3	Irrigation	12
Rural	3	Self-supplied industrial	12
Irrigation	6	Consumption of water not withdrawn	14
Self-supplied industrial	6	Change in withdrawals since 1950	14
Fuel-electric power (public utility).....	7	Supply.....	16
Air conditioning.....	7	Conservation of water	16
Waterpower	7	References cited	17

ILLUSTRATIONS

	Page
Figure 1. Water withdrawn for public supplies.....	4
2. Water withdrawn for rural use.....	5
3. Water withdrawn for irrigation, including conveyance losses	9
4. Self-supplied industrial water	10
5. Water withdrawn in the United States during 1955.....	14
6. Water withdrawn during 1955 for rural use, public supplies, irrigation, and self-supplied industrial use, by regions.....	15

TABLES

	Page
Table 1. Water withdrawn for public supplies, by regions.....	3
2. Water withdrawn for rural use, by regions.....	6
3. Water withdrawn for irrigation, by regions	7
4. Water withdrawn for irrigation, by States.....	8
5. Self-supplied industrial water, by regions	11
6. Water withdrawn by public utilities in generation of fuel-electric power, by regions.....	11
7. Water withdrawn for air conditioning, by regions.....	12
8. Water withdrawn for production of waterpower, by regions	12
9. Withdrawal of water, by States	13
10. Change in withdrawals, 1950-55	16
11. The Nation's water supply.....	16
12. Summary of known artificial recharge during 1955	17

ESTIMATED USE OF WATER IN THE UNITED STATES, 1955

By Kenneth A. MacKichan

ABSTRACT

The estimated withdrawal use of water in the United States during 1955 was about 1,740,000 mgd (million gallons per day). Withdrawal use of water requires that it be removed from the ground or diverted from a stream or lake. In this report it is divided into five types: public supplies, rural, irrigation, self-supplied industrial, and waterpower. Consumptive use of water is the quantity discharged to the atmosphere or incorporated in the products of the process in which it was used. Only a small part of the water withdrawn for industry was consumed, but as much as 60 percent of the water withdrawn for irrigation may have been consumed.

Of the water withdrawn in 1955 about 1,500,000 mgd was for generation of waterpower, and all other withdrawal uses amounted to only about 240,000 mgd. Surface-water sources supplied 194,000 mgd and ground-water sources supplied 46,000 mgd. The amount of water withdrawn in each State and in each of 19 geographic regions is given.

The quantity of water used without being withdrawn for such purposes as navigation, recreation, and conservation of fish and wildlife was not determined. The water surface area of the reservoirs and lakes used to store water for these purposes is sufficiently large that the evaporation from this source is greater than the quantity of water withdrawn for rural and public supplies.

The amount of water used for generation of waterpower has increased 36 percent since 1950. The largest increase, 43 percent, was in self-supplied industrial water. Rural use, excluding irrigation, decreased 31 percent.

The upper limit of our water supply is the average annual runoff, nearly 1,200,000 mgd. The supply is depleted by the quantity of water consumed rather than by the quantity withdrawn. In 1955 about one-fourth of the water withdrawn was consumed. The amount thus consumed is about one-twentieth of the supply.

INTRODUCTION

Water supply is affected by many of man's activities. This report evaluates the effects of only those activities that require the withdrawal of water from surface or underground sources. Nonwithdrawal uses also have appreciable effects, but these are difficult to evaluate in terms of quantity used.

The use of water generally reduces the supply and frequently deteriorates the quality whether the use is withdrawal or nonwithdrawal, consumptive or non-

consumptive. The quality may be adversely affected by addition or concentration of mineral constituents, addition of bacteria or organic matter, or the addition of heat. Because the use of water affects the supply, an adequate evaluation of the Nation's water resources requires a knowledge of the quantity of water used, where it is used, and the type of use.

The purpose of this report is to evaluate the use of water in large geographical areas and in broad categories. The data presented are in sufficient detail for broad planning but not for the evaluation of the water resources of small areas. The magnitude of the quantity of water used for different purposes is shown by States and regions. It also shows the trend in water withdrawals between 1950 and 1955.

Previous Investigations

Until recently few attempts were made to estimate the total quantity of water withdrawn for use in the United States. Some investigators made inventories or estimates of water used by a single industry. The U. S. Public Health Service (1948 and 1955), in cooperation with the sanitary-engineering divisions of the State health departments, made inventories of public water-supply facilities in 1945 and 1954 which included data on the quantity of water used. The U. S. Bureau of the Census (1955) made a survey of water used by the manufacturing industries in 1953, as part of their annual survey of manufactures. Picton (1952 and 1956) made estimates of water used in the United States from 1900 to 1950 and 1955 and forecast estimates of future use. Guyton (1950) made an estimate of ground water used in the United States during 1945, and Langbein (1950) made an estimate of the quantity of water used in the United States in 1946 for the generation of hydroelectric power. An inventory made by Mangan and Graham (1953) showed the quantity of water used in Pennsylvania in 1951. MacKichan (1951) also made an estimate of the quantity of water used in each of the 48 States during 1950 for five major uses, rural, public supplies, industry, irrigation, and waterpower, to which the present inventory is similar in objective and scope.

Present Investigation

This report presents an estimate of the quantity of water withdrawn in 1955 from ground and surface sources. Some water was withdrawn from a source, used, and discharged into a stream or the ground, only to be withdrawn again. Sometimes a subsequent withdrawal was not made directly from a stream or the ground but was made from the returning flow of a previous withdrawal—such as sewage withdrawn for

irrigation. Each time the water was withdrawn it was added to the accumulated total; therefore, the same water was withdrawn several times and was counted each time that it was withdrawn. However, if the water was withdrawn and recirculated, so that it was used several times in the same plant before it was discharged into a stream or the ground, it was counted only once. Although the best information available was used, the estimates in this report are, in general, only approximations of the quantity of water used. The estimate for municipal use is probably the most accurate and that for industrial use the least accurate. Some quantities are given to three or more significant figures because they are the sum of two or more quantities that are given to two significant figures. The quantities presented in this report are not applicable to more than two significant figures.

Estimates of water used are given for the District of Columbia and each State in the continental United States and for the major drainage regions in the United States. The drainage regions are shown in figure 6 and are described as follows:

North Atlantic. North Atlantic slope drainage, Maine to Connecticut.
 Upper Hudson. Hudson River basin above and including Orange and Putnam Counties, N. Y.
 Lower Hudson and coastal area. Hudson River below and including Westchester and Rockland Counties and Long Island; and North Atlantic slope drainage, Hudson River to Delaware River.
 Delaware. Delaware River basin.
 Chesapeake. North Atlantic slope drainage, Chesapeake Bay to York River.
 Southeast. Atlantic slope and Gulf of Mexico drainage, James River to Pearl River.
 Tennessee-Cumberland. Tennessee and Cumberland River basins.
 Ohio. Ohio River basin exclusive of Tennessee and Cumberland River basins.
 Eastern Great Lakes-St. Lawrence. St. Lawrence River basin below the mouth of St. Clair River.
 Western Great Lakes. St. Lawrence River basin above the mouth of St. Clair River.
 Missouri-Hudson Bay. Missouri River basin and Hudson Bay basin.
 Upper Mississippi. Mississippi River basin above the Ohio River and exclusive of the Missouri River basin.
 Lower Mississippi. Mississippi River basin below the Ohio River and exclusive of the Arkansas-White-Red River basins.
 Arkansas-White-Red. Arkansas, White, and Red River basins.
 Western Gulf. Gulf of Mexico drainage, west of the Mississippi Delta.
 Colorado. Colorado River basin.
 Great Basin. The Great Basin.
 Pacific Northwest. Pacific slope drainage north of California.
 South Pacific. Pacific slope drainage in California.

Areas of drainage regions are given in table 11.

District offices of the Water Resources Division of the Geological Survey supplied estimates of water used for public supplies and for manufacturing and nonmanufacturing industries. The estimates were based on data in the Geological Survey files and those furnished by State officials. The quantities of water used for

electric utilities, rural domestic and stock use, and irrigation were computed using statistics of the U. S. Bureau of the Census (1952, 1953, 1955, and 1956), the U. S. Federal Power Commission (1953 and 1955), and the U. S. Department of Agriculture (1955). Information on the sources of water (ground water, surface water, or sewage) was furnished by the district offices of the Water Resources Division of the Geological Survey.

Definition of Terms

Uses of water may be classified in several different ways. Among them are withdrawal and nonwithdrawal uses and consumptive and nonconsumptive uses. Withdrawal uses require that the water be removed from the ground or diverted from a stream or lake. Irrigation, domestic, stock, public, and industrial uses are of this type. Generation of waterpower is also considered a withdrawal use; even in run-of-river plants the water is diverted through the turbines and frequently the generation of waterpower has a very definite effect on the streamflow. The quantity withdrawn is the entire quantity of water taken for use. This quantity is sometimes labeled "pumpage," "water intake," "duty of water," or "water requirement" (Am. Water Works Assoc. Task Group, 1953). Nonwithdrawal uses do not require diversion. Navigation, recreation, waste disposal, and conservation of fish and wildlife are examples of nonwithdrawal uses.

Consumptive use is the quantity of water discharged to the atmosphere or incorporated in the products of the process in connection with vegetative growth, food processing, or incidental to an industrial process (Am. Water Works Assoc. Task Group, 1953).

Saline water has been defined as water containing more than 1,000 ppm (parts per million) of dissolved solids (Krieger, R. A., Hatchett, J. L., and Poole, J. L., 1956) regardless of the composition of the solids and is not necessarily a salty (NaCl) water.

Quantities of water given in this report are generally in million gallons per day (mgd); however, some quantities are also given in acre-feet per year. An acre-foot of water will cover an acre to a depth of 1 foot; 1,000 acre-feet per year equals 0.89 mgd.

WITHDRAWAL USE

Withdrawal uses can be evaluated quantitatively because they require removal of the water from the ground, stream, lake, or reservoir. An evaluation of the total quantity of water withdrawn can be made by adding together the known amounts of withdrawals. The primary withdrawal uses are public supplies, rural domestic and stock irrigation, self-supplied industrial, and waterpower. Although generation of waterpower may be considered a self-supplied industrial use of water, it is treated as a primary withdrawal use in this report because it neither degrades nor consumes the water withdrawn. The primary withdrawal uses may be subdivided. Fuel-electric utilities and air conditioning are important secondary withdrawal uses and, therefore, have been evaluated in this report.

Public Supplies

Public water-supply systems served almost 115 million people an average of 148 gallons per person per day or about 17,000 mgd (fig. 1). Water used for public supplies includes all water pumped into the system. This water may be used for fire protection, street flushing, irrigation of lawns and gardens, and by industrial and commercial establishments as well as for domestic supply. Because the water is measured at the source, leakage is also included. Public water-supply systems may be either publicly or privately owned.

Of the 17,000 mgd withdrawn for public supplies, almost three-fourths was obtained from surface

sources and slightly more than one-fourth was obtained from wells and springs (tables 1 and 9). About one-third of the water withdrawn was used by industrial and commercial establishments.

Rural

About 2,500 mgd was used in rural homes and for stock watering during 1955 (fig. 2). Nearly three-fourths of the water was taken from wells or springs, and slightly more than one-fourth was taken from streams, ponds, and lakes, (tables 2 and 9). Rural homes are defined as those not served by public water-supply systems.

Table 1.—Water withdrawn for public supplies, by regions

Region	Ground water (mgd)	Surface water (mgd)	Total (mgd)	Population served	Use per capita (gpd)	Used by industry (mgd) ^{1/}
North Atlantic.....	120	830	950	8,560,787	111	240
Upper Hudson.....	26	170	196	1,147,080	171	40
Lower Hudson and coastal area	280	2/1,440	2/1,720	13,386,500	128	478
Delaware.....	130	3/590	3/720	5,104,600	141	254
Chesapeake.....	73	790	863	5,826,972	148	360
Eastern Great Lakes and St. Lawrence	120	1,400	1,520	8,060,751	189	940
Western Great Lakes.....	270	1,500	1,770	8,404,200	211	1,000
Upper Mississippi	310	270	580	6,068,674	96	92
Southeast	500	840	1,340	11,230,127	119	320
Tennessee-Cumberland.....	51	190	241	1,629,032	148	50
Ohio.....	420	1,200	1,620	11,361,610	143	480
Missouri-Hudson Bay.....	330	470	800	4,952,283	162	240
Lower Mississippi.....	170	330	500	3,516,600	142	89
Arkansas-White-Red.....	260	350	610	4,499,050	136	110
Western Gulf	590	460	1,050	5,560,630	189	380
Colorado.....	140	4/50	4/190	1,082,960	175	24
Great Basin.....	120	5/100	5/220	744,900	295	22
Pacific Northwest.....	240	580	820	3,237,700	253	320
South Pacific.....	530	6/740	6/1,270	10,621,400	120	300
United States.....	4,700	12,000	17,000	115,000,000	148	5,700

^{1/}The amount used by industry is included in the total and includes water used for air conditioning. (See table 7.)

^{2/}Includes about 350 mgd diverted from Delaware River (New York City Board of Water Supply, 1956).

^{3/}Does not include 350 mgd diverted into the lower Hudson and coastal area (New York City Board of Water Supply, 1956).

^{4/}Does not include about 230 mgd diverted into south Pacific region (California Water Resources Board, 1955).

^{5/}Does not include about 280 mgd diverted into south Pacific region (California Water Resources Board, 1955).

^{6/}Includes about 510 mgd diverted from the Colorado and Great Basin regions (California Water Resources Board, 1955).

ESTIMATED USE OF WATER, 1955




Figure 1.—Water withdrawn for public supplies.




Figure 2.—Water withdrawn for rural use.

Table 2.—Water withdrawn for rural use, in million gallons per day, by region

Region	Ground water	Surface water	Total
North Atlantic.....	27	11	38
Upper Hudson.....	25	2	27
Lower Hudson and coastal area.....	36	1	37
Delaware.....	24	6	30
Chesapeake.....	80	20	100
Eastern Great Lakes and St. Lawrence.....	94	20	114
Western Great Lakes.....	140	24	164
Upper Mississippi.....	210	80	290
Southeast.....	175	65	240
Tennessee-Cumberland.....	41	29	70
Ohio.....	190	64	254
Missouri-Hudson Bay.....	240	140	380
Lower Mississippi.....	38	32	70
Arkansas-White-Red.....	120	79	199
Western Gulf.....	130	28	158
Colorado.....	22	10	32
Great Basin.....	21	18	39
Pacific Northwest.....	61	42	103
South Pacific.....	80	20	100
United States.....	1,800	690	2,500

The rural population of the United States in 1955 was about 47 million. About 20 percent of these people live in homes having running water. Frank (1955) states that people living in the average electrified farm or urban home in the United States use an average of 60 gallons or more each day for household and lawn watering. The corresponding average for homes without running water is only 10 gpd per person. Other investigators report that only 50 gpd per person is used in homes having running water. Assuming these averages, about 970 mgd was used for rural domestic purposes, most of which was from wells.

About 1,500 of the 2,500 mgd was used for stock watering and about 60 percent of the stock water was from wells and springs. The quantity of water used by livestock ranges widely, depending on kind and age of the animal and the air temperature (Sykes, 1955). Several authorities (Sykes, 1955; Marion, 1952; Arkansas-White-Red Basins Inter-Agency Committee, 1957) have given the water requirements of livestock. The per capita rates used in this report were taken from several sources and are given in the following tabulation:

Livestock	Per capita use (gallons per day)
Horses and mules.....	10
Beef cattle.....	10
Milk cows.....	20
Hogs.....	3
Sheep.....	2
Goats.....	2
Chickens.....	.04
Turkeys.....	.06

Irrigation

Water used for irrigation might be defined in at least four ways: that which is transpired or evaporated from a cropped area, that which is delivered to the farms, that which is withdrawn from the source, or the gross over-all supply required. Water delivered to the farms includes evaporation and seepage from the distribution ditches as well as that transpired and evaporated from the cropped areas. Water withdrawn from the source is the water delivered plus conveyance losses. The gross over-all supply is the water withdrawn plus evaporation and seepage from storage reservoirs when such are part of the system.

Most of the water lost in conveyance seeps into the ground and, therefore, is not lost as a resource as it can be recovered through wells. Some water lost in conveyance may be transpired by phreatophytes and cannot be recovered. If the farm irrigation efficiency is high, most of the water delivered to the farm is consumed in growing crops. Therefore, the quantity of water delivered to the farm is an indication of the depletion of the resource, and the quantity of water withdrawn from the streams or wells (water delivered to farms plus conveyance losses) is an indication of the depletion of the stream or aquifer in the vicinity. In this report water withdrawn for irrigation is the amount taken from the source and has been divided into the amount delivered to the farms and the amount lost in conveyance.

About 123 million acre-feet of water was used in 1955 to irrigate 34 million acres. Of this amount 91 million acre-feet was delivered to farms and 32 million acre-feet was lost in conveyance. About 27 percent of the water used came from wells and springs, 73 percent came from surface sources, and less than 0.1 percent was sewage (tables 3, 4, and 9). Most of the irrigation was in the Western States (fig. 3).

Irrigation water is usually measured in acre-feet per year. However, in this report it is given also in average million gallons per day so that the quantities can be compared with and added to quantities of water used for other purposes. Irrigation water is applied during only a part of each year, and at variable rates; therefore, the actual rate of application is much greater than the average daily rate given in tables 3 and 9.

Self-Supplied Industrial

Water has many industrial uses, including processing, cooling, conveyance of material, boiler feed, and sanitation. Some industries require water of very high quality whereas to other industries water quality is relatively unimportant. Most industrial water is self-supplied although a small amount is purchased from public supplies (table 1). Industry used an average of 110,000 mgd during 1955. Most self-supplied industrial water, 91 percent, was from surface sources. Underground sources supplied 9 percent, and less than 0.1 percent was reclaimed sewage (tables 5 and 9). Most industrial water is used in the States east of the Mississippi River (fig. 4).

A large part of the industrial water is used for cooling and is returned to a stream or an aquifer

WITHDRAWAL USE

7

Table 3.—Water withdrawn for irrigation, by regions

Region	Delivered to farms						Conveyance losses					
	Ground water		Surface water		Reclaimed sewage		Ground water		Surface water		Reclaimed sewage	
	1,000 acre-ft per year	Average (mgd)	1,000 acre-ft per year	Average (mgd)	1,000 acre-ft per year	Average (mgd)	1,000 acre-ft per year	Average (mgd)	1,000 acre-ft per year	Average (mgd)	1,000 acre-ft per year	Average (mgd)
North Atlantic.....	2.0	1.8	20	18	0	0	0	0	0	0	0	0
Upper Hudson.....	2.5	2.2	2.9	2.6	0	0	0	0	0	0	0	0
Lower Hudson and coastal area.....	25	22	24	21	0	0	0	0	0	0	0	0
Delaware.....	17	16	18	16	0	0	0	0	0	0	0	0
Chesapeake.....	2.5	2.2	28	25	0	0	0	0	0	0	0	0
Eastern Great Lakes and St. Lawrence..	7.2	6.5	19	17	0	0	0	0	0	0	0	0
Western Great Lakes.....	8.1	7.3	49	43	0	0	0	0	0	0	0	0
Upper Mississippi.....	15	12	19	17	0	0	0	0	.1	.08	0	0
Southeast.....	310	280	340	300	.05	.04	4.7	4.2	15	12	0	0
Tennessee-Cumberland.....	2.4	2.2	28	25	0	0	0	0	0	0	0	0
Ohio.....	7.7	7.0	18	16	0	0	0	0	0	0	0	0
Missouri-Hudson Bay.....	1,800	1,600	11,000	10,000	7.4	6.6	200	190	7,100	6,200	1.9	1.7
Lower Mississippi.....	650	580	400	350	0	0	74	65	130	120	0	0
Arkansas-White-Red.....	3,300	3,000	1,300	1,200	4.2	3.8	360	330	290	260	1.0	.91
Western Gulf.....	6,100	5,500	5,000	4,600	35	31	1,200	1,100	1,400	1,200	8.0	7.1
Colorado.....	4,500	4,000	11,000	9,500	17	16	900	800	2,500	2,100	2.4	2.1
Great Basin.....	1,200	1,000	8,300	7,500	0	0	280	250	2,900	2,500	0	0
Pacific Northwest.....	1,500	1,300	17,000	15,000	7.1	6.4	200	180	10,000	9,300	3.1	2.8
South Pacific.....	8,300	7,400	8,400	7,500	22	19	2,300	2,000	2,700	2,400	5.8	5.2
United States.....	28,000	25,000	63,000	56,000	93	83	5,500	4,900	27,000	24,000	22	20

unchanged except for an increase in temperature. Cooling water does not need to be of high quality; some cooling equipment is designed for use of sea water or other saline water.

Fuel-Electric Power (Public Utility)

The amount of water used by public utilities for fuel-electric power was almost twice the amount of self-supplied industrial water used by other industries (table 5). About 94 percent of the water used by public utilities for generation of fuel-electric power was for condenser cooling (table 6), and the remaining 6 percent was for other uses, such as boiler feed, sanitary services, cooling of machinery within the plant, and irrigation of lawns. Two percent of the condenser cooling water was obtained from wells or springs and 98 percent from surface sources. Almost all of the ground water was fresh, but about 17 percent of the surface water was saline. The only use made of saline water was in condensers.

The quantity of water used per kilowatt hour of electric power generated by steam plants varies widely. According to the Arkansas-White-Red Basins Inter-Agency Committee (1957), in those basins plants that do not recirculate water used from 40 to 280 gallons per kilowatt hour and averaged 91 gallons per kilowatt hour. The Committee also reported that the plants that recirculate water used from 0.5 to 9.2 gallons per kilowatt hour and averaged 0.9 gallon per kilowatt hour. Most of the water used in plants that recirculate water was evaporated, whereas most of the water used without recirculation was discharged to a stream. Most plants in areas of abundant water supply do not recirculate water. In the Arkansas-White-Red River basins about two-thirds of the fuel-electric power is generated in plants that recirculate the water (Arkansas-White-Red Basins Inter-Agency Committee, 1957).

Air Conditioning

Almost half (490 mgd) of the water used for air conditioning is taken from public supplies and most of the remainder is from privately owned wells (table 7). The 490 mgd is part of the 5,700 mgd taken from public supplies and used by industry (table 1). The remaining 590 mgd is part of the 110,000 mgd of self-supplied industrial water reported in table 5. The quantities of water used for air conditioning are annual rates. Air conditioning is highly seasonal, with most of the water used in a 4 to 6 month period each year. Therefore, during the air-conditioning season water is used at a much higher rate than that shown in table 7, and during the remainder of the year little or no water is used. The increased draft on public supplies for water for air conditioning during hot weather is a serious problem in some places. During a 10-day hot period in September 1955 the draft on the public-supply system of Pasadena, Calif., reached a maximum daily rate of 430 gallons per capita (Blackburn, 1956). The average daily use in Pasadena during the year 1954-55 was only 178 gallons per capita.

Waterpower

About 1,600 million acre-feet of water was used during 1955 to generate waterpower (tables 8 and 9). The rate of use is variable and depends on the water available and the demand for power. The quantities of water were computed with the aid of two publications of the U. S. Federal Power Commission (1953 and 1955). The average plant efficiency and other factors were estimated. Much of the water was used more than once.

Summary of Withdrawals

The estimated withdrawal of water in the United States amounted to about 1,740,000 mgd during 1955.

ESTIMATED USE OF WATER, 1955

Table 4.—Water withdrawn for irrigation, in thousand acre-feet per year, by States

State	Delivered to farms			Conveyance losses		
	Ground water	Surface water	Sewage	Ground water	Surface water	Sewage
Alabama.....	2.7	15	0	0	0	0
Arizona.....	4,400	2,000	10	880	480	1.5
Arkansas.....	880	98	0	2.6	.39	0
California.....	8,800	12,000	22	2,400	3,200	5.9
Colorado.....	980	5,000	3.0	200	1,000	.60
Connecticut.....	1.5	13	0	0	0	0
Delaware.....	.43	1.4	0	0	0	0
District of Columbia.....	0	0	0	0	0	0
Florida.....	280	270	0	2.6	11	0
Georgia.....	14	20	.05	0	0	0
Idaho.....	1,100	10,000	0	110	5,100	0
Illinois.....	3.6	5.4	0	0	0	0
Indiana.....	5.7	3.7	0	0	0	0
Iowa.....	3.8	1.3	0	0	0	0
Kansas.....	680	150	0	0	0	0
Kentucky.....	4.4	5.0	0	0	0	0
Louisiana.....	430	540	0	0	390	0
Maine.....	.21	.75	0	0	0	0
Maryland.....	.75	15	0	0	0	0
Massachusetts.....	.20	4.6	0	0	0	0
Michigan.....	6.0	47	0	0	0	0
Minnesota.....	2.5	7.5	0	0	0	0
Mississippi.....	440	300	0	74	48	0
Missouri.....	22	27	0	0	0	0
Montana.....	110	5,500	3.6	54	5,300	3.6
Nebraska.....	910	790	0	37	1,200	0
Nevada.....	200	1,500	7.0	33	410	.70
New Hampshire.....	.02	1.0	0	0	0	0
New Jersey.....	25	17	0	0	0	0
New Mexico.....	1,200	950	12	300	320	3.7
New York.....	25	28	0	0	0	0
North Carolina.....	1.6	8.6	0	0	0	0
North Dakota.....	1.6	80	0	0	58	0
Ohio.....	1.2	11	0	0	0	0
Oklahoma.....	170	61	0	0	22	0
Oregon.....	360	4,100	4.0	190	3,000	0
Pennsylvania.....	1.8	16	0	0	0	0
Rhode Island.....	.05	.50	0	0	0	0
South Carolina.....	13	20	0	0	0	0
South Dakota.....	7.0	18	0	.70	6.3	0
Tennessee.....	4.1	27	0	0	0	0
Texas.....	6,100	3,400	27	1,200	690	5.3
Utah.....	280	3,300	.20	28	1,100	.10
Vermont.....	0	1.2	0	0	0	0
Virginia.....	.48	7.6	0	0	0	0
Washington.....	250	2,700	0	1.5	2,700	0
West Virginia.....	0	.92	0	0	0	0
Wisconsin.....	2.9	7.2	0	0	0	0
Wyoming.....	26	9,900	3.9	5.3	2,000	.80
United States.....	28,000	63,000	93	5,500	27,000	22




Figure 3.—Water withdrawn for irrigation including conveyance losses.

ESTIMATED USE OF WATER, 1955




Figure 4.—Self-supplied industrial water.

WITHDRAWAL USE

11

Table 5. —Self-supplied industrial water, in million gallons per day, by regions

Region	Fuel-electric power (public utility)						Other							Total		
	Ground water			Surface water			Ground water		Surface water			Re-claimed sewage	Ground water	Surface water	Total	
	Fresh	Saline	Total	Fresh	Saline	Total	Fresh	Saline	Total	Fresh	Saline					Total
North Atlantic.....	1	0	1	870	1,900	2,770	140	7	147	1,500	450	1,950	0	148	4,720	4,868
Upper Hudson.....	2	0	2	410	0	410	12	0	12	580	0	580	0	14	990	1,004
Lower Hudson and Coastal area.....	150	1	151	900	2,500	3,400	240	7	247	830	1,600	2,430	0	398	5,830	6,228
Delaware.....	16	0	16	2,140	480	2,620	250	4	254	1,100	850	1,950	0	270	4,570	4,840
Chesapeake.....	41	0	41	1,074	760	1,834	200	3	203	870	740	1,610	68	244	3,444	3,756
Eastern Great Lakes and St. Lawrence.....	250	0	250	6,110	0	6,110	140	5	145	2,500	0	2,500	0	395	8,610	9,005
Western Great Lakes.....	249	0	249	9,390	0	9,390	210	21	231	2,900	0	2,900	0	480	12,290	12,770
Upper Mississippi.....	440	0	440	5,960	0	5,960	460	15	475	1,400	0	1,400	.7	915	7,360	8,276
Southeast.....	174	0	174	6,160	1,040	7,200	1,000	18	1,018	1,300	130	1,430	0	1,192	8,630	9,822
Tennessee-Cumberland.....	44	0	44	2,730	0	2,730	120	0	120	1,800	0	1,800	0	164	4,530	4,694
Ohio.....	580	0	580	14,470	0	14,470	820	15	835	6,000	6	6,006	0	1,415	20,476	21,891
Missouri-Hudson Bay.....	360	0	360	2,422	0	2,422	390	6	396	1,000	3	1,003	0	756	3,425	4,181
Lower Mississippi.....	314	0	314	1,319	58	1,377	470	0	470	1,300	0	1,300	0	784	2,677	3,461
Arkansas-White-Red.....	146	0	146	1,003	52	1,055	330	45	375	400	2	402	0	521	1,457	1,978
Western Gulf.....	159	0	159	1,444	510	1,954	460	500	960	1,200	1,900	3,100	.5	1,119	5,054	6,173
Colorado.....	25	0	25	18	0	18	140	0	140	96	0	96	0	165	114	279
Great Basin.....	40	0	40	51	0	51	100	0	100	60	0	60	0	140	111	251
Pacific Northwest.....	15	0	15	304	66	370	370	0	370	760	33	793	0	385	1,163	1,548
South Pacific.....	210	0	210	530	4,700	5,230	230	0	230	76	550	626	.3	440	5,856	6,296
United States.....	3,200	1	3,200	57,000	12,000	69,000	6,100	650	6,700	26,000	6,200	32,000	70	9,900	100,000	110,000

Table 6. —Water withdrawn by public utilities in generation of fuel-electric power, in million gallons per day, by regions.

Region	Condenser cooling						Other uses		All uses	
	Ground water			Surface water			Fresh ground water	Fresh surface water	Ground water	Surface water
	Fresh	Saline	Total	Fresh	Saline	Total				
North Atlantic.....	0	0	0	710	1,900	2,610	1	160	1	2,770
Upper Hudson.....	0	0	0	390	0	390	2	21	2	411
Lower Hudson and coastal area.....	0	1	1	850	2,500	3,350	150	50	151	3,400
Delaware.....	0	0	0	2,000	480	2,480	16	140	16	2,620
Chesapeake.....	3	0	3	1,000	760	1,760	38	74	41	1,834
Eastern Great Lakes and St. Lawrence.....	110	0	110	5,900	0	5,900	140	210	250	6,110
Western Great Lakes.....	39	0	39	9,100	0	9,100	210	290	249	9,390
Upper Mississippi.....	230	0	230	5,800	0	5,800	210	160	440	5,960
Southeast.....	14	0	14	5,900	1,040	6,940	160	260	174	7,200
Tennessee-Cumberland.....	0	0	0	2,600	0	2,600	44	130	44	2,730
Ohio.....	220	0	220	14,000	0	14,000	360	470	580	14,470
Missouri-Hudson Bay.....	220	0	220	2,400	0	2,400	140	22	360	2,422
Lower Mississippi.....	240	0	240	1,300	58	1,358	74	19	314	1,377
Arkansas-White-Red.....	66	0	66	990	52	1,042	80	13	146	1,055
Western Gulf.....	19	0	19	1,400	510	1,910	140	44	159	1,954
Colorado.....	10	0	10	18	0	18	15	0	25	18
Great Basin.....	27	0	27	50	0	50	13	1	40	51
Pacific Northwest.....	0	0	0	290	66	356	15	14	15	370
South Pacific.....	100	0	100	420	4,700	5,120	110	110	210	5,230
United States.....	1,300	1	1,300	55,000	12,000	67,000	1,900	2,200	3,200	69,000

Of this amount, about 1,500,000 mgd was withdrawn for production of waterpower (table 9). The 240,000 mgd remaining was withdrawn for public supplies, rural use, self-supplied industrial and irrigation, including conveyance losses (fig. 5) which amounted to 1,500 gallons per capita per day. Surface-water sources supplied 194,000 of the 240,000 mgd, and ground-water sources supplied 46,000 mgd.

About equal quantities of water, 110,000 mgd, were withdrawn for self-supplied industry and irrigation. About 17,000 mgd was withdrawn for public supplies and the smallest quantity, 2,400 mgd, was withdrawn for rural domestic and stock use. The withdrawal of water was greatest in the eastern industrial areas and in western areas where irrigation is practiced extensively (fig. 6). Withdrawals in the midcontinent region were the smallest.

Table 7.—Water withdrawn for air conditioning, in million gallons per day, by regions

Region	Self-supplied industrial water ^{1/}		Public supplies ^{2/}	Total
	Ground water	Surface water		
North Atlantic.....	0	0	0	0
Upper Hudson.....	2	4	3	9
Lower Hudson and Coastal area.	55	37	53	145
Delaware.....	21	13	20	54
Chesapeake.....	7	4	28	39
Eastern Great Lakes and St. Lawrence.	18	2	7	27
Western Great Lakes.	14	45	21	80
Upper Mississippi..	8	0	43	51
Southeast.....	110	14	42	166
Tennessee-Cumberland.	10	9	11	30
Ohio.....	22	7	32	61
Missouri-Hudson Bay.	11	6	22	39
Lower Mississippi..	44	15	27	86
Arkansas-White-Red.	20	8	51	79
Western Gulf.....	20	1	45	66
Colorado.....	12	2	6	20
Great Basin.....	4	0	4	8
Pacific Northwest..	4	0	3	7
South Pacific.....	36	0	70	106
United States.....	420	170	490	1,100

^{1/}See table 5.^{2/}Water from public supplies used for air conditioning is part of the 5,700 mgd used by industry. (See table 1.)

NONWITHDRAWAL USES

Nonwithdrawal uses do not lend themselves to evaluation in terms of the quantity of water used. These uses, however, do have a very large economic value and may have an appreciable effect on the quantity and quality of water available for other uses. The most important nonwithdrawal uses are navigation, waste disposal, recreation, and conservation of fish and wildlife.

CONSUMPTIVE USE

Only about a fourth of all withdrawn water is consumed. Consumption, expressed as a percentage of withdrawals, depends on many factors, including climate, season, and the use of the water. Most of the water consumed is used for irrigation; a fact of added importance when we consider that irrigation is practiced at times and places where the water supply is likely to be inadequate. Generally a higher percentage of the water withdrawn is consumed in areas having a dry climate than in humid areas, and a higher percentage is consumed in the hot dry part of the year.

Public Supplies

Not much of the water withdrawn by public supplies is consumed; Jordan (1955) estimated that not more

than 10 percent of it fails to reach watercourses below the cities. A larger percentage of the water is probably consumed during the summer when lawns are watered.

Rural

The principal rural uses are stock watering and domestic. Water withdrawn for domestic use probably is consumed at about the same rate as water from public supplies; that is, about 10 percent of the withdrawals. Nearly all the water withdrawn for stock watering is consumed.

Irrigation

Irrigation is considered a consumptive use, although a large part of the water may reach a stream or the water table as return flow. Generally not more than 60 percent of the water delivered at the farm head gate is consumed by the crops (Blaney, 1955). If a sprinkler irrigation system is used, a much greater percentage of the water applied is transpired or evaporated.

Self-Supplied Industrial

The amount of self-supplied industrial water consumed is small, although the percentage of the amount withdrawn varies widely among industrial plants. For example, Mussey (1955) reported that in the manufacture of paper about 690 gallons of water per ton of paper was evaporated, which amounts to less than 2 percent of the plant intake. On the other hand, Conklin (1956) reported that almost all process water used in the production of carbon black was consumed, although the amount used was small. Only about 2 percent of all self-supplied industrial water is consumed.

Table 8.—Water withdrawn for production of water-power, by regions

Region	Million gallons per day	1,000 acre-feet per year
North Atlantic.....	180,000	200,000
Upper Hudson.....	35,000	39,000
Lower Hudson and coastal area.	1,200	1,400
Delaware.....	1,700	1,900
Chesapeake.....	73,000	82,000
Southeast.....	110,000	120,000
Tennessee-Cumberland.....	210,000	230,000
Ohio.....	48,000	54,000
Eastern Great Lakes and St. Lawrence.	100,000	110,000
Western Great Lakes.....	89,000	99,000
Upper Mississippi.....	130,000	140,000
Missouri-Hudson Bay.....	46,000	51,000
Lower Mississippi.....	0	0
Arkansas-White-Red.....	11,000	13,000
Western Gulf.....	9,300	10,000
Colorado.....	26,000	29,000
Great Basin.....	8,100	9,000
Pacific Northwest.....	360,000	410,000
South Pacific.....	32,000	36,000
United States.....	1,500,000	1,600,000




Figure 5. —Water withdrawn in the United States during 1955.

Consumption of Water Not Withdrawn

In addition to the consumption of part of the water withdrawn, large quantities of water stored for withdrawal and nonwithdrawal uses are consumed. Storage in farm ponds and reservoirs increases the water surface area and consequently the evaporation. If the pond or reservoir was created or enlarged to serve a use, then the increased evaporation can logically be charged to consumption rather than natural loss. Consumption of water not withdrawn has not been determined, however, it must be large.

The surface area of reservoirs gives an indication of the quantity of water evaporated. In 1954, there were 1,300 reservoirs and lakes in the United States having a capacity greater than 5,000 acre-feet and storing water for navigation, irrigation, power, water supply, flood control, and other uses (Thomas and Harbeck, 1956). These lakes and reservoirs had a total surface area of more than 11 million acres. The

evaporation from an area of this size would amount to more than the quantity of water withdrawn for public supplies. In addition to the larger reservoirs reported by Thomas and Harbeck, the U. S. Fish and Wildlife Service (1956) estimates there are more than $1\frac{1}{2}$ million farm ponds averaging an acre each. The aggregate annual evaporation from these ponds exceeds that withdrawn for rural use exclusive of irrigation.

CHANGE IN WITHDRAWALS SINCE 1950

This survey is comparable to the 1950 survey, except that it includes irrigation conveyance losses not given in the 1950 survey, and it probably is a little more accurate. Of the increases in water withdrawals since 1950, the greatest increase, 43 percent, was in self-supplied industrial water (table 10). Rural use declined between 1950 and 1955, because of the decrease in the number of people living in areas classed as rural.




Figure 6.—Water withdrawn during 1955 for rural use, public supplies, irrigation, and self-supplied industrial use, by regions.

Table 10.—Change in withdrawals, 1950-55

	Water used (mgd)		Percent change
	1950	1955	
Waterpower.....	1, 100, 000	1, 500, 000	+36
Rural.....	3, 600	2, 500	-31
Public supplies.....	14, 000	17, 000	+21
Self-supplied industrial.	77, 000	110, 000	+43
Irrigation (except conveyance losses).	79, 000	81, 000	+3
Total, other than waterpower.	173, 600	210, 500	+21

Although the increase in surface water used, exclusive of that for waterpower, was 26, 000 mgd and that of ground water was 11, 000 mgd, the greater percentage increase was in water from ground-water sources, 37 percent as compared with 18 percent in surface water.

SUPPLY

Much of the withdrawn water is not consumed and therefore the supply is not depleted by the amount withdrawn. For this reason the quantity of withdrawn water is not directly comparable with the supply and, in fact, may exceed the total supply owing to repeated use. On the other hand, water that is consumed by use is no longer available; consequently, consumptive use can be compared with supply.

The long-term average runoff of a river basin, with few exceptions, is the upper limit of possible production of the combined surface- and ground-water resources of the basin. The exceptions are in the narrow fringes along the coasts where some water that percolates underground directly into the ocean could be used without affecting runoff, provided such use does not cause contamination by sea water. Runoff is the total flow of a stream including outflow from ground-water storage through springs and seeps as well as the overland flow that follows hard rains.

The runoff of all streams in the United States average 1, 164, 000 mgd, but it is not uniformly distributed throughout the Nation (table 11). The average annual runoff ranges from less than one-fourth inch in several places in the Southwest to more than 80 inches at some places along the Pacific Coast. In addition to this great areal variation in average annual runoff, runoff varies widely from day to day and year to year in any one locality. Therefore, a substantial part of the runoff cannot be used economically because it occurs as flood flow in such large volumes that storage is not feasible. The amount that can be used, however, could be increased by the use of above-ground and underground storage.

Table 11. —The Nation's water supply

Region	Area (thousand square miles)	Water supply ^{1/}	
		Inches per year	Million gallons per day
North Atlantic.....	59	24	67, 000
Upper Hudson.....	13	22	14, 000
Lower Hudson and coastal area.	6	21	6, 000
Delaware.....	12	21	12, 000
Chesapeake.....	57	19	51, 000
Eastern Great Lakes and St. Lawrence.	47	18	40, 000
Western Great Lakes..	81	11	42, 000
Upper Mississippi.....	182	7. 2	62, 000
Southeast.....	279	16	212, 000
Tennessee-Cumberland.	59	21	59, 000
Ohio.....	145	16	110, 000
Missouri-Hudson Bay..	580	1. 9	52, 000
Lower Mississippi.....	64	16	49, 000
Arkansas-White-Red..	270	7. 0	90, 000
Western Gulf.....	341	3. 2	52, 000
Colorado.....	258	1. 1	13, 000
Great Basin.....	200	1. 1	10, 000
Pacific Northwest.....	257	13	159, 000
South Pacific.....	112	12	64, 000
United States.....	3, 022	8. 5	1, 164, 000

^{1/}Adapted from Langbein (1949) by James K. Searcy.

CONSERVATION OF WATER

Our water supply is a renewable resource because it is replenished frequently by precipitation. As water is a renewable resource, it cannot be hoarded ordinarily by nonuse. There are two important exceptions: stored ground water that is being mined and ground water that is being pumped at such a rate as to allow saline water encroachment to cause permanent contamination.

Mining water is the withdrawal of water accumulated over a long period of time, in the same sense that any other mineral resource is mined. For example, ground water that has accumulated for many centuries in the High Plains of Texas now is being used for irrigation with the full knowledge that, once the ground-water reservoir is depleted, it may be centuries before it can be filled again. Mining is a good conservation practice if the present use of the water results in the greatest foreseeable benefit.

Reducing or preventing contamination of ground water by saline waters or industrial wastes conserves water. In some places fresh ground water has been replaced or contaminated by encroaching saline water. This occurs when fresh water is

pumped from wells in large quantities allowing adjacent saline water to flow into the aquifers from which the fresh water was removed. The saline water may come from other aquifers below or above the fresh-water aquifer, by seepage or through improperly constructed or corroded well casings, or from the sea in coastal areas.

Water can be conserved in many other ways. Reservoirs can be built to hold back flood waters until they are needed. Better use can be made of the large ground-water reservoirs. Also, where geologic conditions permit, water can be stored in ground-water reservoirs by means of artificial recharge. Artificial recharge averaged at least as much as 700 mgd in 1955 (table 12). Most artificial recharge was

practiced in California using surface water. Return water from air conditioners, industrial waste, and sewage are also sources of water for artificial recharge.

Water can be conserved by keeping permanent waste to a minimum. This can be accomplished by constructing reservoirs where the evaporation from its water surface is as small as possible and by reducing the growth of phreatophytes. We can obtain more service from our water supply by using water of inferior quality where it is possible to do so, such as for condenser cooling, in order to leave purer water for a use requiring a water of better quality. Recirculating water in industrial plants and preventing or reducing pollution from domestic sewage and industrial wastes are other conservation measures.

Table 12.—Summary of known artificial recharge during 1955, in million gallons per day

Region	Air-conditioning return	Industrial wastes	Surface water	Public water supplies	Other	Total
North Atlantic.....	0	0	4.0	0	0	4.0
Upper Hudson.....	0	0	0	0	0	0
Lower Hudson and coastal area.....	24	31	49	2	0	106
Delaware.....	1	1	2	0	0	4
Chesapeake.....	.3	0	0	0	0	.3
Eastern Great Lakes and St. Lawrence.....	4.1	0	0	0	0	4.1
Western Great Lakes.....	6.0	3.5	0	0	0	9.5
Upper Mississippi.....	0	1.0	6.4	0	0	7.4
Southeast.....	2.0	.25	0	.1	0	2.35
Tennessee-Cumberland.....	.5	0	0	0	0	.5
Ohio.....	.5	2.6	30	0	0	33.1
Missouri-Hudson Bay.....	0	0	.5	0	0	.5
Lower Mississippi.....	0	0	0	0	0	0
Arkansas-White-Red.....	0	4.2	0	0	0	4.2
Western Gulf.....	0	0	0	0	0	0
Colorado.....	.2	0	0	0	0	.2
Great Basin.....	2.7	0	0	0	0	2.7
Pacific Northwest.....	0	5.8	71	8.8	.2	85.8
South Pacific.....	0	0	375	60	0	435
United States.....	41	49	540	71	0.2	700

REFERENCES CITED

- American Water Works Association Task Group, 1953, Water conservation in industry: Am. Water Works Assoc. Jour., v. 45, no. 12, p. 1249-1260.
- Arkansas-White-Red Basins Inter-Agency Committee, 1957, Development of water and land resources of the Arkansas-White-Red River basins: 85th Cong. 1st sess., S. Doc 13.
- Blackburn, D. A., 1956, Discussion of air conditioning and water supply, Round table, Water Works Engineering, v. 109, no. 5, p. 465.
- Blaney, H. F., 1955, Climate as an index of irrigation needs, in *Water, The Yearbook of Agriculture*: p. 341-345.
- California Water Resources Board, 1955, Water Utilization and requirements of California, Calif. Water Resources Board Bull. 2 v. 1, p. 227.
- Conklin, H. L., 1956, Water requirements of the carbon-black industry: U. S. Geol. Survey Water-Supply Paper 1330-B, p. 73-100.
- Frank, Bernard, 1955, The story of water as the story of man, in *Water, The Yearbook of Agriculture*: p. 1-8.
- Guyton, W. F., 1950, Estimated use of ground water in the United States, 1945: U. S. Geol. Survey, open-file report.
- Jordan, H. E., 1955, The problems that face our cities, in *Water, The Yearbook of Agriculture*: p. 649-653.
- Krieger, R. A., Hatchett, J. L., and Poole, J. L., 1956, Preliminary survey of the saline-water resources of the United States, U. S. Geol. Water-Supply Paper 1374 (in press).
- Langbein, W. B., 1950, An American survey: *Water Power*, v. 2, no. 6, London, England, p. 238-245.
- Langbein, W. B., and others, 1949, Annual runoff in the United States: U. S. Geol. Survey Circ. 52, 14 p.
- McKichan, K. A., 1951, Estimated use of water in the United States—1950: U. S. Geol. Survey Circ. 115, 13 p.
- Mangan, J. W., and Graham, J. B., 1953, The use of water in Pennsylvania, 1951: U. S. Geol. Survey Circ. 257, 11 p.
- Marion, A. W., 1952, The water situation and Ohio agriculture, in the *Proceedings of the First Ohio Water Clinic*, Ohio State Univ., Eng. Expt. Sta. Bull. 147, p. 21-26.

- Mussey, O. D., 1955, Water requirements of the pulp and paper industry: U. S. Geol. Survey Water-Supply Paper 1330-A, p. 1-71.
- New York City Board of Water Supply, 1956, Fiftieth annual report, 1955: New York City Board of Water Supply, 108 p.
- Picton, W. L., 1952, The national picture: Ill. State Water Survey Pull. 41, p. 127-130.
- 1956, Summary of information on water use in the United States, 1900-1975: U. S. Dept. of Commerce Business Service Pull. 136, 6 p.
- Sykes, J. F., 1955, Animals and fowl and water, in Water, The Yearbook of Agr.: p. 14-18.
- Thomas, N. O., and Harbeck, G. E., Jr., 1956, Reservoirs in the United States: U. S. Geol. Water-Supply Paper 1360-A, p. 1-29.
- United States Bureau of the Census, 1952, United States Census of Agriculture: 1950, Irrigation of agricultural lands.
- 1953, Census of population, 1950, v. 2, Characteristics of the population.
- United States Bureau of the Census, 1955, Statistical abstract of the United States, 76th ed.
- 1956: 1954 Census of Agriculture.
- United States Department of Agriculture, Agriculture Marketing Service, Crop Reporting Board, 1955, Livestock and poultry on farms and ranches, Jan. 1.
- United States Federal Power Commission, 1953, Hydroelectric power resources of the United States, developed and undeveloped, 1953.
- 1955, Electric power statistics.
- United States Fish and Wildlife Service, 1956, Farm ponds get increasing attention from Fish and Wildlife Service: Dept. of Interior press notice 97569, Apr. 15, 1956.
- United States Public Health Service, 1948, Inventory of water and sewage facilities in the United States, 1945.
- 1955, Inventory municipal water facilities for larger communities, 1954.