



State of South Carolina Water Resources Commission

P.O. Box 4515 / 3830 Forest Drive / Columbia, S.C. 29240 / (803) 758-2514

144 RIBAULT SQ., BEAUFORT, S. C. 29902 - 524-1995



WATER WELL REPORT

OWNER'S NO.

COUNTY NO.

BFT-1840

SCWRC NO.

27JJ-14

A. GENERAL

1. Lat-Long: 321820 804123 2. Map: Parris Island 3. Location: Parris Is. Golf Course
4. Well use: ps() ind() irr() stk() fire() dom() rec() obs() pab() abn() des() unu() stb()
 Remarks: Beaufort-Jasper Regional Ground Water Study Observation Well
5. Drainage Basin: 03050208 6. Topography: draw() h-top() hillside() valley() flat() depression()
7. Owner: SCWRC/USGS Phone: 524-1995
 Address: 144 Ribault Square, Beaufort, South Carolina 29902
8. Engineer: _____ Phone: _____
 Address: _____
9. Source of Data: _____ Phone: _____

B. WELL CONSTRUCTION DATA

1. Contractor: C. W. Lusby Drilling Company, Inc. Phone: (806) 792-9422
 Address: 3311 - 88th Street, Lubbock, Texas 79423
2. Driller: C. W. Lusby 3. Date started: 10-22-86 Completed: 11-4-86 4. Const. Diag.: Yes No
5. Method Drilled: Mud rotary () Cable tool() Augered() Other _____
6. Hole Size: Dia(in) 10" from 0' to 250' Type bit: _____ Time _____
5 7/8" 250' 602'
7. Well Depth (ft.): Rept. 602' Test hole: _____ Completed: _____ Measured _____
8. Method Developed: Pump() Horiz. jet() Air surge() Other _____ Time _____
9. Drill Mud Type/Brand: Bentonite/Quik Gel Total weight used: _____
10. Grout Type: Neat Method: Pressure Vol: 3.5 yd³ Thickness: 2" Depth: 0' to 250'
11. Casing Dia.(in.): 6" Depth: 0' to 250' Wght ft. or Wall Thick: _____ Type: Steel Meth. install: _____
12. Screen Record: open hole () Remarks: open to lower unit Aq.: Floridan
 Dia.: _____ Depth: _____ to _____ Type: _____ Mat: _____ Slot: _____ Aq.: _____
 (in.) (ft.)

13. Filter: _____ Method: _____ Vol: _____ Thickness: _____ Depth: _____ to _____