



State of South Carolina Water Resources Commission

P.O. Box 4515 / 3830 Forest Drive / Columbia, S.C. 29240 / (803) 758-2514



WATER WELL REPORT

OWNER'S NO.

COUNTY NO.

BPT-1845

SCWRC NO.

2843-95

A. GENERAL

1. Lat-Long: 321540 804510 2. Map: Spring Island 3. Location: Victoria Bluff
4. Well use: ps () ind () irr () stk () fire () dom () rec () obs (X) pab () abn () des () unu () stb ()
Remarks: Beaufort-Jasper Regional Ground Water Study observation well
5. Drainage Basin: 03650208 6. Topography: draw () hilltop () hillside () valley () flat (X) depression ()
7. Owner: LEASEE - Waddell Mariculture Center Phone: 837-3795
Address: Post Office Box 809, Bluffton, South Carolina 29910
8. Engineer: (CONTACT) Steve Hopkins Phone: 837-3795
Address: _____
9. Source of Data: _____ Phone: _____

B. WELL CONSTRUCTION DATA

1. Contractor: C. W. Lusby Drilling Company, Inc. Phone: (806) 792-9422
Address: 3311 - 88th Street, Lubbock, Texas 79423
2. Driller: C. W. Lusby 3. Date started: 11-13-86 Completed: 11-24-86 4. Const. Diag.: Yes (X) No ()
5. Method Drilled: Mud rotary (X) Cable tool () Augered () Other _____
6. Hole Size: Dia.(in.): 10" from 0' to 320' Type bit: _____ Time: _____
5 7/8" 320' 600'
7. Well Depth (ft.): Rept. 600' Test hole: _____ Completed: _____ Measured: _____
8. Method Developed: Pump () Horiz. jet () Air surge (X) Other _____ Time: _____
9. Drill Mud Type/Brand: Bentonite/Quik Gel Total weight used: _____
10. Grout Type: Neat Method: Pressure Vol: 4.5 yd³ Thick(in.): 2" Depth(ft.): 0' to 320'
11. Casing Dia.(in.): 6" Depth: 0' to 255' Wght./ft.: _____ Type: PVC Meth. install.: _____
or Wall Thick
12. Screen Record: open hole (X) Remarks: Lower unit well Aq: Floridan
Dia. (in.): _____ Depth (ft.): 320 to _____ Type: _____ Mat.: _____ Slot (in.): _____ Aq: _____

13. Filter: Type _____ Method: _____ Vol: _____ Thick(in.): _____ Depth(ft.): _____ to _____