

SOURCES OF EMERGENCY WATER SUPPLIES IN NAPA VALLEY, CALIFORNIA

By D. A. Webster

INTRODUCTION

Many water-supply systems in the San Francisco Bay region are vulnerable to failures resulting from earthquakes, nuclear explosions, floods, or acts of civil disorder. Yet few, if any, of the water-supply agencies maintain adequate standby sources of water, or have prepared detailed plans that consider alternative sources of water supply. It is the purpose of this report to present sufficient information for Napa Valley to facilitate the development by local officials of an emergency water-supply plan for that area. The report presents general criteria for sources of emergency water supply and data for selected wells in Napa Valley. The need for obtaining similar data for other parts of the Bay region is recognized, but cannot be accomplished under the present series of planning studies. Nevertheless, this report may serve as a guide for similar studies elsewhere.

The report was prepared by the U.S. Geological Survey in cooperation with the Department of Housing and Urban Development as part of the San Francisco Bay Region Environment and Resources Planning Study. This investigation was made in the spring of 1972 under the general supervision of L. R. Peterson, district chief in charge of water-resources investigations in California, and under the immediate supervision of L. R. Young, chief of the Napa Park subdistrict.

PRINCIPAL SOURCES OF EXISTING WATER SUPPLY

The water supplies for the majority of the residents in Napa Valley are obtained from surface-water sources. The city of Napa obtains its water from Lake Hennessey, from Milliken Reservoir, and from the Dutch South Canal terminal wastewater near Cordelia. Yountville obtains its water from Rector Reservoir, and St. Helena obtains its water from York Creek. Calistoga obtains its water from a reservoir formed by Kimball Canyon dam and from a municipal well (number 23 on map and in the table).

Small towns, unincorporated communities, and persons living outside of municipal water-service areas depend chiefly upon wells to supply water for domestic, stock, and other uses.

CRITERIA FOR SOURCES OF EMERGENCY WATER SUPPLY

Surface-water supplies from reservoirs, lakes, or streams can be readily destroyed, contaminated, or otherwise rendered unusable as a result of a disaster. In contrast, ground water cannot be lost suddenly, and water in deeper aquifers cannot be readily contaminated by a disaster. Wells drawing their water supplies from other than shallow aquifers, therefore, generally provide a satisfactory and reliable source for an emergency water supply.

The suitability of a well for inclusion in an emergency water-supply plan depends on the intended use of the water and on several characteristics of the well. For emergency domestic use, such factors as well yield, construction, source, power, electrical characteristics, and water quality are important. For general-utility use, such as for washing, flushing, or firefighting, little or no importance may be associated with the construction and water-quality characteristics.

Well yield.—The yield of a well is useful for determining the volume of water that can be pumped during a specific period of time and for estimating the number of people that may be supplied from the well. For example, a well pumping 100 gpm (gallons per minute) over a 12-hour period will yield 72,000 gallons of water. This amount is more than adequate for supplying the minimum daily drinking water requirements (1 quart per person per day) of the valley's present population. A realistic emergency water-supply plan, however, should include sufficient water to meet cooking and cleansing requirements (drinking, cooking, and surface water) for 3 days. The U.S. Office of Civil Defense Mobilization at 5-15 gpm per person per day, plus additional water for most general utility needs.

Construction.—Good well construction provides sanitary protection and guards against contamination of the water and of the well and aquifers. Thus, it is important to apply protective measures in constructing all wells. Although it is impractical to establish fixed well specifications that fit every local situation, there are fundamental principles that can ensure a sanitary installation at reasonable cost. These wells constructed to, or to, the following standards, which largely follow the sets forth by the California Department of Water Resources (1968), have greatest potential as sources of emergency domestic supply.

A well should be drilled on ground higher than nearby sources of contaminants and the well casing should terminate above ground. Where necessary, the ground surface at the well site should be built up with a gently sloping surface of several yards radius to facilitate the drainage of surface water away from the well in all directions. This precaution would have particular importance during a period of rain following a nuclear explosion for any contaminants would then tend to move away from the wellhead before entering the well.

The space between the well casing and the wall of the drilled hole (annular space) should be sealed to a depth of about 50 feet to protect against contamination by the downward movement of surface water, contaminated ground water, or other undesirable fluid through the annular space to the intake part of the well. As a general rule, wells without surface or sanitary seals and wells that obtain water from depths less than about 50 feet below land surface should not be used until the water has been tested and declared safe for human consumption. In Napa Valley the thickness of the seal appears to be less critical, for many domestic-supply wells of the area have been sealed only to depths of 20 to 30 feet below land surface and apparently yield water satisfactory for drinking.

In addition, the well should be constructed so that it denies entry to any contaminated or undesirable water contained in the water-bearing deposits.

REFERENCES

- Basic water facts, principles, and problems:**
- Baldwin, H. L., and McGinness, C. L., 1963, A primer on ground water: Washington, U.S. Govt. Printing Office, U.S. Geol. Survey misc. rept., 26 p.
 - Leopold, L. B., and Langbein, W. B., 1960, A primer on water: Washington, U.S. Govt. Printing Office, U.S. Geol. Survey misc. rept., 30 p.
 - Sweeney, H. A., and Baldwin, H. L., 1965, A primer on water quality: Washington, U.S. Govt. Printing Office, U.S. Geol. Survey misc. rept., 27 p.
 - U.S. Department of Agriculture, 1955, Water: Yearbook of agriculture for 1955: Washington, U.S. Govt. Printing Office, 731 p.
- Technical and scientific background:**
- Bryan, E. N., 1932, Report of the Napa Valley investigation: California Division of Water Resources, 70 p.
 - Butler, R. C., Orlob, G. T., and McManis, P. H., 1954, Underground movement of bacterial and chemical pollutants: Jour. Am. Water Works Assoc., v. 46, no. 2, p. 97-111.
 - California Department of Water Resources, 1968, Water well standards: Bull. 74, 205 p.
 - (Published annually, 1963 to present), Hydrologic data: Bull. 130.
 - Kunkel, Fred, and Upson, J. R., 1960, Geology and ground water in Napa and Sonoma Valleys, Napa and Sonoma Counties, California: U.S. Geol. Survey Water-Supply Paper 1495, 232 p.
 - Miller, J. R., and Reimender, R. P., 1963, The leaching of radionuclides and radionuclides through soil: Soil Sci. Soc. America Proc., v. 27, no. 2, p. 141-144.
 - Romero, J. C., 1970, The movement of bacteria and viruses through porous media: Urbana, Ill., Ground Water, v. 8, no. 2, p. 37-48.
 - U.S. Environmental Protection Agency, 1971, Manual evaluating public drinking water supplies: 62 p. Previously published in 1969 as U.S. Public Health Service Pub. 1620.
 - U.S. Office of Civil and Defense Mobilization, 1959, Minimum portable water supply requirements in civil defense emergencies: Jour. Am. Water Works Assoc., v. 51, no. 8, p. 964-966.
 - 1966, Civil defense aspects of waterworks operations: Pub. For-3-0, 85 p.
 - U.S. Public Health Service, 1962, Public Health Service drinking water standards: Public Health Service Pub. no. 956, 61 p.

DATA FOR EMERGENCY WATER-SUPPLY WELLS

State well number: Each well is identified according to its location in the rectangular system for the subdivision of public land. For example, in the number 58/44-32A1, the part of the number preceding the slash indicates the township (T. 5 N.) north of the Mt. Diablo base line, and the number between the slash and the hyphen indicates the range (R. 4 W.) west of the Mt. Diablo meridian; the number between the hyphen and letter indicates the section (sec. 30), and the letter (A) indicates the 40-acre subdivision of the section as shown in the accompanying diagram. The final digit is a serial number for each well in a 40-acre subdivision. The location of the well is shown on the map by a number as indicated below.

D	C	B	A
T	R	S	1
N	W	E	1
S	P	Q	R

Type of pump: S, submersible; T, turbine.

Well-construction data:

Surface seal: No, yes; U, unknown; F, unknown but probable.

Source of power:

Voltage requirement: s, single-phase source; t, three-phase source.

Map well number	State well number	Owner or manager	Type of pump	Well yield (gpm)	Well-construction data				Source of power	Voltage requirement	Accessibility	Use of water		Remarks
					Surface seal	Depth intake part of well (feet)	Reported depth of well (feet)	Accessability				Existing	Emergency	
Pumps operated by electric motors														
1	58/44-32A1	Carneros Elementary School	S	30	Yes	260	Yes	220,s		In unfenced area beside pump-house, adjacent to Los Carneros Avenue.	PS	1	Water chlorinated and stored in 1,000-gallon tank inside pump-house.
2	58/44-34B1	Sanitation District, City of Napa	S	300	Yes	220	500	Yes	220,t		In fenced enclosure. Access by unpaved road.	In,PS	2	Also known as "Adams & Forbes No. 8." Water pumped to a 35,000-gallon tank.
3	58/44-24B1	Bay West Rock Co., Inc., Napa	T	700	U	1,440	Yes	440,t		In open area about 0.1 mile west of State Highway 12 and 29. Access by unpaved road.	In,PS	1	Also known as "Adams & Forbes No. 7." Casing cemented to a depth of 391 feet.
4	58/44-24B1	do.	T	250	Yes	391(?)	806	Yes	440,t		In fenced enclosure at Kaiser Steel Corporation field.	In,PS	1	Also known as "Big Garden Well"; has served as source of supply for Napa State Hospital. Flowing at less than 1 gpm, 2-29-72. Water is warm (80°F), but satisfactory for domestic use.
5	58/44-23F1	Napa College, Napa	T	300-350	F	323	No	440,t		In pump-house about 200 feet south of Strawberry Drive.	U	4	Also known as "Little Garden Well"; has served as source of supply for Napa State Hospital. Flowing at less than 1 gpm, 2-29-72. Water is warm (80°F), but satisfactory for domestic use.
6	58/44-14P1	do.	T	400-500	F	160	600	No	440,t		In pump-house northwest of Napa College parking lot. Access by unpaved road.	U	4	Also known as "Big Garden Well"; has served as source of supply for Napa State Hospital. Flowing at less than 1 gpm, 2-29-72. Water is warm (80°F), but satisfactory for domestic use.
7	58/44-14L1	Napa State Hospital, Napa	T	400	F	525	No	440,t		In pump-house on west side of State Highway 12 and 29. Access by unpaved road.	U	3	Also known as "Little Garden Well"; has served as source of supply for Napa State Hospital. Water is warm (82°F), but satisfactory for domestic use.
8	58/44-12H1	Mr. George Union Elementary School	S	35	F	478	Yes	220,s		In pump-house north of school buildings and 30 feet west of Second Avenue.	PS	1	Water chlorinated and stored in tank outside pump-house.
9	68/44-2312	Silverado Country Club, Napa	T	600-800	Yes	170	850	Yes	440,t		In open area on west side of Acton Peak Road.	U	1	Well covered by 2-foot square wooden cover set in sand surface; not readily visible.
10	68/44-2313	do.	T	1,200	U	Yes	440,t		In open area on small island.	Ir	5	Two other large-yield wells with electrically-operated turbine pumps are located on south side of road.
11	68/44-2302	do.	T	1,000	U	Yes	440,t		In open area near rest room.	Ir	5	
12	68/44-2302	do.	T	1,000	U	Yes	440,t		In open area beside pond.	Ir	5	
13	68/44-22B4	Soda Canyon Elementary School	S	Yes	284	Yes	220,t		In pump-house southwest of school building.	PS	1	Water chlorinated and stored in 1,000-gallon tank inside pump-house.
14	68/44-4P1	Chimney Rock Golf Course, Napa	S	100-150	U	20	320	Yes	440,t		In open area about 60 feet east of No. 3 green.	Ir	1	Wellhead and plumbing at land surface; not readily visible.
15	68/44-9B1	do.	S	100-300	Yes	20	335	Yes	440,t		In open area about 115 feet northwest of No. 7 green.	Ir	1	Well covered by 2-foot square wooden cover set in sand surface; not readily visible.
16	68/44-9B2	do.	S	100-300	Yes	20	460	Yes	440,t		In open area about 160 feet west-southwest of No. 8 green.	Ir	1	Two other large-yield wells with electrically-operated turbine pumps are located on south side of road.
17	68/44-4D1	St. Joan of Arc Church, Yountville	T	400-700	Yes	40	300	Yes	440,t		In open area 0.4 mile north-east of church, on north side of paved road.	Ir	1	Two other large-yield wells with electrically-operated turbine pumps are located on south side of road.
18	78/34-23C1	Edward Bernard, Rutherford	T	980	Yes	50	390	Yes	440,t		In open area, on east side of Money Road about 500 feet north of intersection with Oakville Cross Road.	A	1	
19	88/44-23E1	Harold Varozza, St. Helena	S	160	Yes	65	270	Yes	220,t		In open area behind residence at 492 Pratt Avenue.	D,Ir	1	Well flows at low rate during period of non-use.
20	88/44-15C2	Pacific Gas and Electric Co., St. Helena	S	70	Yes	20	80	Yes	220,t		In fenced area adjacent to south side of building.	PS,Ir	1	Three other wells owned by Sterling Vineyards are located 0.3 to 0.4 mile east, on north side of road. Wells are equipped with submersible pumps, do not have surface seals, and yield 100, 150, and 200 gpm.
21	88/44-5P1	Sterling Vineyards, Calistoga	S	200	Yes	44	300	Yes	440,t		In open area at base of hill and about 100 feet north of paved road to vineyard office.	A	1	Auxiliary power available at fairgrounds. Water reported warm. Several wells have been drilled at golf course and fairgrounds, but all other wells are reported to terminate in the first aquifer and yield water contaminated by septic-tank effluent.
22	98/34-39B1	Mr. St. Helena Golf Course, Calistoga	S	5-40	Yes	Yes	110,s		In open area on golf course and near north bank of Napa River.	PS,Ir	2	Water chlorinated and pumped to 1 million-gallon storage tank at the well. Water used seasonally in conjunction with reservoir water. Second well drilled nearby, but not equipped with a pump as of February 1972.
23	88/34-201	Calistoga Water Department, Calistoga	S	100-150	Yes	240	350(?)	Yes	220,t		In open area. Access by unpaved road.	PS	1	Water chlorinated and stored in 1,000-gallon tank inside pump-house.
Pumps operated by diesel-powered engines														
24	68/44-1704	Trefethen Vineyards, Napa	T	500	No	61	203	No	--		In pump-house north of vineyard office. Access by unpaved road.	A	3	Several other wells equipped with electrically-operated turbine pumps are located in vineyard.
25	68/44-8L1	Vinfiera Development Corp., Rutherford	T	1,500	U	No	--		In open area beside south bank of unnamed stream channel. Access by unpaved road.	A	5	
26	78/34-3A1	Gladys Beard, Yountville	T	3,200	No	222	No	--		In open area. Access by unpaved road.	A	3	
27	68/34-1D1	Edward Bernard, Rutherford	T	3,500	No	190	496	No	--		In fenced enclosure. Access by unpaved road.	A	4	Water has sulphurous taste. Reported to flow at 100 gpm during slack irrigation season.
28	78/34-5A7	Christian Brothers, St. Helena	T	3,200	No	81	546	No	--		In pump-house in vineyard. Access by unpaved road from railroad.	A	3	
29	88/34-32J1	do.	T	1,500	No	26	458	No	--		In pump-house beside White Lane (unpaved).	A	5	City of St. Helena sewage pond is located about 700 feet north. Water may require boiling or chlorination before public use.
30	88/34-32Q1	do.	T	800	No	55	435	No	--		do.	A	5	Do.
Pumps operated by natural gas-powered engines														
31	78/34-3J1	Elwood Mees, Rutherford	T	800-1,200	No	110	459	No	--		In pump-house beside levee along north bank of Napa River. Access by unpaved road from New Lane.	A	5	
32	88/34-33B3	Freemack Abbey Winery, St. Helena	T	1,100	No	100	350	No	--		In pump-house. Access by unpaved road from Zinfandel Lane.	A	3	

