Water use in Lee during 2003.

[--, no data; UNH, University of New Hampshire; BRW, indicates well in bedrock aquifer; gal/d, gallons per day]

Water system name / Well or surface-water body name	Population or number of employees	Water use in million gallons per day (Mgal/d)					
		Withdrawals	Delivery	Demand	Collection	Return flow	Consumptive use
COMMUNITY WATER SYSTEMS							
UNH/Durham Water System	0						
Lee Well (export to Durham)		0.222	-0.222				
Cedar Wood Estates	50						
BRW 1		0.004					
Darby Field Commons	70						
BRW 1		0.002					
BRW 2		0.002					
Evergreen Terrace	45						
BRW		0.004					
Greystone Commons	25						
BRW 1		0.002					
Oyster River Condo	53						
BRW		0.004					
Pine Knoll Village	200						
BRW 1		0.008					
BRW 2		0.008					
Total	**443**	**0.258**					
Type of user	**Population or number of employees**	**Withdrawals**	**Delivery**	**Demand**	**Collection**	**Return flow**	**Consumptive use**
WATER USE							
Domestic users	4,145			0.309			0.060
Public supply (81 gal/d per capita)	443		0.036	0.036			0.007
Self supply (74 gal/d per capita)	3,702	0.273		0.273			0.053
Sewered	0				0.000		
Septic (60 gal/d per capita)	4,145					0.249	
Industrial users - unknown				0.001			0.000
Public supply - 0	0		0.000	0.000			0.000
Self supply -	--	0.001		0.001			0.000
Sewered - 0	0				0.000		
Septic -	--					0.001	
Commercial users - 5				0.020			0.002
Public supply - 0	0		0.000	0.000			0.000
Self supply - 5	150	0.020		0.020			0.002
Sewered - 0	0				0.000		
Septic - 5	150					0.018	
Irrigation users - 1				0.001			0.000
Ground-water self supply - 1	12	0.001		0.001			0.000
Ground-water return -1						0.000	
COMMUNITY WASTEWATER SYSTEMS							
No community wastewater systems							
WATER-USE SUMMARY							
Surface water	**0**	--	--	--	--	--	--
Ground water	**4,145**	**0.553**	**0.036**	**0.331**	--	**0.268**	**0.062**
Public-supply use			0.036	0.036			0.007
Self-supplied use		0.295		0.295			0.055
Public-sewer releases					0.000		
Septic releases						0.268	
Unaccounted-for use						0.000	
Inflow and infiltration		0.000					
Consumptive use							0.062
TRANSFER							
Export from town: 0.222 Mgal/d							
Import to town: 0.000 Mgal/d							